

Sample Range Report

Fraser Health Authority

Facility Name: Hemlock Water System
Date Range: Jan 1 2014 to Dec 31 2014

Operator Jesse Crawford
 20955 Hemlock Valley Rd
 Agassiz, BC V0M 1A1

Sampling Site	Date Collected	Total Coliform	E. Coli	Fecal Coliform
<u>Subdivision 6,</u>				
	2/12/2014	3	1	
	3/12/2014	L1	L1	
	4/30/2014	2	L1	
	6/17/2014	3	L1	
	8/26/2014	23	L1	
	12/10/2014	<u>6</u>	<u>L1</u>	
	Total Positive:	5	1	0
<u>Subdivision 5,</u>				
	1/15/2014	7	L1	
	1/28/2014	L1	L1	
	2/26/2014	L1	L1	
	3/26/2014	L1	L1	
	6/4/2014	4	L1	
	6/11/2014	L1	L1	
	6/25/2014	L1	L1	
	8/6/2014	<u>44</u>	<u>4</u>	
	Total Positive:	3	1	0
<u>Day Lodge,</u>				
	1/15/2014	2	L1	
	1/28/2014	L1	L1	
	4/30/2014	L1	L1	
	7/15/2014	L1	L1	
	8/19/2014	L1	L1	
	9/23/2014	<u>EST 250</u>	<u>EST 1</u>	
	Total Positive:	2	1	0
<u>Condos,</u>				
	1/15/2014	2	L1	
	2/5/2014	L1	L1	
	3/12/2014	L1	L1	
	5/6/2014	2	L1	
	5/13/2014	L1	L1	
	5/28/2014	10	L1	
	8/12/2014	EST 180	EST 2	

9/2/2014	EST 330	EST 4	
9/9/2014	EST 240	EST 16	
10/14/2014	EST 160	EST 2	
12/3/2014	<u>L1</u>	<u>L1</u>	
Total Positive:	7	4	0

Maintenance Shop.

1/29/2014	L1	L1	
3/12/2014	L1	L1	
5/20/2014	4	L1	
6/4/2014	L1	L1	
7/8/2014	L1	L1	
7/30/2014	EST 78	EST 5	
11/19/2014	<u>L1</u>	<u>L1</u>	
Total Positive:	2	1	0

Result Values: E - estimated L - less than G - greater than

Samples that contain total coliform:	19		50.00% of total
Samples that contain e. coli:	8		21.05% of total
Samples that contain fecal coliform:	0		0.00% of total
Number of consecutive samples that contain total coliform:	7		
Number of samples that contain total coliform in last 30 days:	1/2		
Total number of samples:	38		

Comments:

Environmental Health Officer
Jan 14 2015

FOR FURTHER INFORMATION PLEASE CALL: Jeniene Lutz (604) 870-7900